



CITY OF LIMA, OHIO

David J. Berger, Mayor

50 Town Square Lima Ohio 45801-4900 419/228-5462 Fax 419/221-5214
www.cityhall.lima.oh.us

July 18, 2017

Ms. Peggy Christie
Ohio EPA
347 North Dunbridge Road
Bowling Green, OH 43402-9398

Re: NPDES Permit No. 2PE00000*MD
Preliminary Compliance Report


Dear Ms. Christy,

This letter is in response to the Compliance Review Report for the City of Lima's WWTP, dated July 17, 2017. The compliance issue identified in the report pertained to Overflow Volumes at station 002 and 003.

The volume of the overflow at these stations is not available due to sensor replacement and computer programming. You, along with the US EPA, attended the site visit of these stations on June 20, 2017, and observed the new Rosemont 5400 sensors in place. Per email contact with you and Ms. Works at OEPA, it was determined that the "AD" code should be utilized for this occurrence. The sensor programming is on schedule to be completed by July 20, 2017. The sensors have not been programmed for the first two weeks of July and this same code will appear in the July e-DMR.

Please contact this office if you have any questions.

Thank you.


Eric Markley
Supervisor WWTP

cc: Mike H. Caprella, Utilities Director
Saul E. Allen, Utilities Deputy Director
David L. Schnipke, Environmental Compliance Manager
File