



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director
January 29, 2013

RECEIVED

JAN 31 2013

OHIO E.P.A.
N.W.D.C.

Re: Ohio EPA Permit No.2PE00000*MD
Application No.OH0026069
Facility Name: City of Lima WWTP

Mayor and Council, City of Lima
Attn: WWTP Superintendent
50 Town Square
Lima, OH 45801

Ladies and Gentlemen:

We propose to make to following minor modification to the above referenced permit.

Page Correction

- 14 Change last paragraph of notes section for Station 581 regarding Fecal Coliform Monitoring;
- 25 Extend months in Part I, C. - Schedule of Compliance Item 1.a.i. from 6 months to 10 months, Item 1.a.ii. From 9 months to 13 months, and Item 1.a.iii. From 14 months to 18 months

If you consent to this change, please sign below and incorporate the corrected page into your permit. The proposed minor modification will become effective on the date we receive this signed letter from you at the following address: Ohio Environmental Protection Agency, Division of Surface Water, Permit Administration Section, P. O. Box 1049, Columbus, Ohio 43266-0149.

Sincerely,

Ed Swindall, Supervisor
Permit Processing Unit
Division of Surface Water

ERS/ kep

Enclosure

CERTIFIED MAIL

I consent to the minor modification.

Name

Title

Date

Part I, C - Schedules

1. Construction Schedule for Wet Weather Improvements - Specific Projects to be Implemented according to Items a. through i. below

a. Collett Street Sewer Lining

- i. Commence construction as soon as possible, but no later than 9 months from the effective date of this permit. (Event Code 03099)
- ii. Complete construction as soon as possible, but no later than 12 months from the effective date of this permit. (Event Code 04599)
- iii. Notify Ohio EPA, Northwest District Office, Division of Surface Water within 7 days of completing construction.

b. Time-critical Lift Station Projects - These include the Allentown Road Pump Station, Cable Road Pump Station, Gloria Avenue Pump Station, Lost Creek Pump Station, Hickory Knoll Pump Station and the Sugar Street Pump Station.

- i. Submit a permit-to-install application and detail plans as soon as possible, but no later than 10 months from the effective date of this permit. (Event Code 01299)
- ii. Advertise for construction bids, receive bids, and award contracts as soon as possible, but not later than 13 months from the effective date of this permit. (Event Code 01899)
- iii. Commence construction as soon as possible, but no later than 18 months from the effective date of this permit. (Event Code 03099)
- iv. Complete construction as soon as possible, but no later than 24 months from the effective date of this permit. (Event Code 04599)
- v. Notify Ohio EPA, Northwest District Office, Division of Surface Water within 7 days of completing construction.

c. Baxter Street Interceptor Work

- ii. Advertise for construction bids, receive bids, and award contracts as soon as possible, but not later than 4 months from the effective date of this permit. (Event Code 01899)
- iii. Submit a status report on awarding construction contracts as soon as possible, but not later than 16 months from the effective date of this permit. [Event Code 95999].
- iv. Commence construction as soon as possible, but no later than 21 months from the effective date of this permit. (Event Code 03099)

- Sludge fee weight means sludge weight, in dry U.S. tons, excluding any admixtures such as liming material or bulking agents.
- See Part II, Items R, S, T, U, and V.
- To sample for fecal coliform, the treatment plant should collect and analyze a grab sample every other day over a two-week period for a total of seven grab samples, when practical. Each of the grab samples shall be analyzed independently to determine the MPN/g (or CFU/g when applicable) of fecal coliform in the individual sample. The geometric mean of those results shall be reported on the DMR. Each fecal coliform sample must be delivered to the analytical lab within six hours after the sample has been collected, in accordance with the requirements for Part 9921E or Part 9222D, "Standard Methods for the Examination of Water and Wastewater." This process must be completed prior to sewage sludge being removed from the treatment facility.



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director
February 8, 2013

RECEIVED

FEB 12 2013

OHIO E.P.A.
N.W.D.O.

NPDES Permit No. 2PE00000*MD
Application No. OH0026069
Facility Name: City of Lima WWTP

Gary Sheely
City of Lima WWTP
50 Town Square
Lima, OH 45801

Ladies and Gentlemen:

An administrative error was found on the minor modification letter of January 29, 2013. The letter referenced changes from the wrong item number. Instead of changes from Part I. C, "Item 1.a.i-iii.", it should be listed as "Item 2.a.i-iii." Enclosed is a revised copy of the letter. The permit pages sent with the original letter were correct. If you wish to re-sign the enclosed letter and return it to us, an envelope has been provided.

Thank you for your cooperation in this matter. If you have any questions, please do not hesitate to call me at (614) 644-2031.

Sincerely,

A handwritten signature in cursive script that reads 'Ed Swindall'.

Ed Swindall, Supervisor
Permit Processing Unit
Division of Surface Water

ERS/kep

Enclosure

CERTIFIED MAIL



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director
January 29, 2013

Re: Ohio EPA Permit No.2PE00000*MD
Application No.OH0026069
Facility Name: City of Lima WWTP

Mayor and Council, City of Lima
Attn: WWTP Superintendent
50 Town Square
Lima, OH 45801

Ladies and Gentlemen:

We propose to make to following minor modification to the above referenced permit.

Page Correction

- 14 Change last paragraph of notes section for Station 581 regarding Fecal Coliform Monitoring;
- 25 Extend months in Part I, C. - Schedule of Compliance Item 1.b.i. from 6 months to 10 months, Item 1.b.ii. From 9 months to 13 months, and Item 1.b.iii. From 14 months to 18 months

If you consent to this change, please sign below and incorporate the corrected page into your permit. The proposed minor modification will become effective on the date we receive this signed letter from you at the following address: Ohio Environmental Protection Agency, Division of Surface Water, Permit Administration Section, P. O. Box 1049, Columbus, Ohio 43266-0149.

Sincerely,

Ed Swindall, Supervisor
Permit Processing Unit
Division of Surface Water

ERS/ kep

Enclosure

CERTIFIED MAIL

I consent to the minor modification.

Name

Title

Date

- Sludge fee weight means sludge weight, in dry U.S. tons, excluding any admixtures such as liming material or bulking agents.
- See Part II, Items R, S, T, U, and V.
- To sample for fecal coliform, the treatment plant should collect and analyze a grab sample every other day over a two-week period for a total of seven grab samples, when practical. Each of the grab samples shall be analyzed independently to determine the MPN/g (or CFU/g when applicable) of fecal coliform in the individual sample. The geometric mean of those results shall be reported on the DMR. Each fecal coliform sample must be delivered to the analytical lab within six hours after the sample has been collected, in accordance with the requirements for Part 9921E or Part 9222D, "Standard Methods for the Examination of Water and Wastewater." This process must be completed prior to sewage sludge being removed from the treatment facility.

Part I. C - Schedules

1. Construction Schedule for Wet Weather Improvements - Specific Projects to be Implemented according to Items a. through i. below

a. Collett Street Sewer Lining

- i. Commence construction as soon as possible, but no later than 9 months from the effective date of this permit. (Event Code 03099)
- ii. Complete construction as soon as possible, but no later than 12 months from the effective date of this permit. (Event Code 04599)
- iii. Notify Ohio EPA, Northwest District Office, Division of Surface Water within 7 days of completing construction.

b. Time-critical Lift Station Projects - These include the Allentown Road Pump Station, Cable Road Pump Station, Gloria Avenue Pump Station, Lost Creek Pump Station, Hickory Knoll Pump Station and the Sugar Street Pump Station.

- i. Submit a permit-to-install application and detail plans as soon as possible, but no later than 10 months from the effective date of this permit. (Event Code 01299)
- ii. Advertise for construction bids, receive bids, and award contracts as soon as possible, but not later than 13 months from the effective date of this permit. (Event Code 01899)
- iii. Commence construction as soon as possible, but no later than 18 months from the effective date of this permit. (Event Code 03099)
- iv. Complete construction as soon as possible, but no later than 24 months from the effective date of this permit. (Event Code 04599)
- v. Notify Ohio EPA, Northwest District Office, Division of Surface Water within 7 days of completing construction.

c. Baxter Street Interceptor Work

- ii. Advertise for construction bids, receive bids, and award contracts as soon as possible, but not later than 4 months from the effective date of this permit. (Event Code 01899)
- iii. Submit a status report on awarding construction contracts as soon as possible, but not later than 16 months from the effective date of this permit. [Event Code 95999].
- iv. Commence construction as soon as possible, but no later than 21 months from the effective date of this permit. (Event Code 03099)



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director
January 29, 2013

FEB - 5 REC'D

RECEIVED

FEB 07 2013

OHIO E.P.A.
N.W.D.O.

Re: Ohio EPA Permit No.2PE00000*MD
Application No.OH0026069
Facility Name: City of Lima WWTP

Mayor and Council, City of Lima
Attn: WWTP Superintendent
50 Town Square
Lima, OH 45801

Ladies and Gentlemen:

We propose to make to following minor modification to the above referenced permit.

Page Correction

- | | |
|----|---|
| 14 | Change last paragraph of notes section for Station 581 regarding Fecal Coliform Monitoring; |
| 25 | Extend months in Part I, C. - Schedule of Compliance Item 1.a.i. from 6 months to 10 months, Item 1.a.ii. From 9 months to 13 months, and Item 1.a.iii. From 14 months to 18 months |

If you consent to this change, please sign below and incorporate the corrected page into your permit. The proposed minor modification will become effective on the date we receive this signed letter from you at the following address: Ohio Environmental Protection Agency, Division of Surface Water, Permit Administration Section, P. O. Box 1049, Columbus, Ohio 43266-0149.

Sincerely,

Ed Swindall, Supervisor
Permit Processing Unit
Division of Surface Water

ERS/ kep

Enclosure

CERTIFIED MAIL

I consent to the minor modification.

Name GARY A. Sheely

Director of UTILITIES
Title

1-30-2013
Date

- Sludge fee weight means sludge weight, in dry U.S. tons, excluding any admixtures such as liming material or bulking agents.
- See Part II, Items R, S, T, U, and V.
- To sample for fecal coliform, the treatment plant should collect and analyze a grab sample every other day over a two-week period for a total of seven grab samples, when practical. Each of the grab samples shall be analyzed independently to determine the MPN/g (or CFU/g when applicable) of fecal coliform in the individual sample. The geometric mean of those results shall be reported on the DMR. Each fecal coliform sample must be delivered to the analytical lab within six hours after the sample has been collected, in accordance with the requirements for Part 9921E or Part 9222D, "Standard Methods for the Examination of Water and Wastewater." This process must be completed prior to sewage sludge being removed from the treatment facility.

Part I, C - Schedules

1. Construction Schedule for Wet Weather Improvements - Specific Projects to be Implemented according to Items a. through i. below

a. Collett Street Sewer Lining

- i. Commence construction as soon as possible, but no later than 9 months from the effective date of this permit. (Event Code 03099)
- ii. Complete construction as soon as possible, but no later than 12 months from the effective date of this permit. (Event Code 04599)
- iii. Notify Ohio EPA, Northwest District Office, Division of Surface Water within 7 days of completing construction.

b. Time-critical Lift Station Projects - These include the Allentown Road Pump Station, Cable Road Pump Station, Gloria Avenue Pump Station, Lost Creek Pump Station, Hickory Knoll Pump Station and the Sugar Street Pump Station.

- i. Submit a permit-to-install application and detail plans as soon as possible, but no later than 10 months from the effective date of this permit. (Event Code 01299)
- ii. Advertise for construction bids, receive bids, and award contracts as soon as possible, but not later than 13 months from the effective date of this permit. (Event Code 01899)
- iii. Commence construction as soon as possible, but no later than 18 months from the effective date of this permit. (Event Code 03099)
- iv. Complete construction as soon as possible, but no later than 24 months from the effective date of this permit. (Event Code 04599)
- v. Notify Ohio EPA, Northwest District Office, Division of Surface Water within 7 days of completing construction.

c. Baxter Street Interceptor Work

- ii. Advertise for construction bids, receive bids, and award contracts as soon as possible, but not later than 4 months from the effective date of this permit. (Event Code 01899)
- iii. Submit a status report on awarding construction contracts as soon as possible, but not later than 16 months from the effective date of this permit. [Event Code 95999].
- iv. Commence construction as soon as possible, but no later than 21 months from the effective date of this permit. (Event Code 03099)