

Certificate of Analysis

Apr 20, 2026

Laboratory No. W-260410-016
Company GOOGLE CLB - 1 (C008798)
Address 225 RATHMELL RD, 43137-9324,
Account Manager Brad Eckenrode
Request Date Apr 10, 2026
Sample Class Water

Analysis	CLB1- CITY- (L)	CLB1- MCP3- (L)
	Apr 09, 2026	Apr 09, 2026
Lab pH	7.48	8.34
Conductivity	709 umho	2720 umho
P-Alkalinity, as CaCO ₃	<1 mg/L	4.4 mg/L
M-Alkalinity, as CaCO ₃	40 mg/L	168 mg/L
Calcium Hardness, as CaCO ₃	76 mg/L	331 mg/L
Magnesium Hardness, as CaCO ₃	30 mg/L	133 mg/L
Iron, as Fe	<0.01 mg/L	0.01 mg/L
Total Iron, as Fe	<0.01 mg/L	0.09 mg/L
Copper, as Cu	<0.01 mg/L	<0.01 mg/L
Zinc, as Zn	0.17 mg/L	0.36 mg/L
Sodium, as Na	115 mg/L	462 mg/L
Potassium, as K	3.6 mg/L	14 mg/L
Chloride, as Cl	70 mg/L	249 mg/L
Sulfate, as SO ₄	195 mg/L	795 mg/L
Nitrate, as NO ₃	0.83 mg/L	2.2 mg/L
Ortho-Phosphate, as PO ₄	1.4 mg/L	4.3 mg/L
Silica, as SiO ₂	3.4 mg/L	14 mg/L
Total Phosphate, as PO ₄	1.4 mg/L	5.8 mg/L
Total Phosphorus, as P	0.46 mg/L	1.9 mg/L
Fluoride, as F	0.68 mg/L	2.5 mg/L

Comments

Respectfully Submitted,



Joel Phillips

Director, Analytical Lab
ChemTreat International, Inc.

Certificate of Analysis

Apr 20, 2026

Laboratory No. W-260410-016
Company GOOGLE CLB - 1 (C008798)
Address 225 RATHMELL RD, 43137-9324,
Account Manager Brad Eckenrode
Request Date Apr 10, 2026
Sample Class Water

Analysis	CLB1- CITY- (L)	CLB1- MCP3- (L)
	Apr 09, 2026	Apr 09, 2026
Bromide, as Br	<0.1 mg/L	<0.5 mg/L
Ammonia, as NH3	-	<0.1 mg/L
Aluminum, as Al	<0.01 mg/L	0.01 mg/L
Barium, as Ba	<0.01 mg/L	0.04 mg/L
Manganese, as Mn	<0.01 mg/L	<0.01 mg/L
Molybdenum, as Mo	-	<0.05 mg/L
Strontium, as Sr	0.46 mg/L	1.7 mg/L
TOC	1.1 mg/L	15 mg/L
Total Suspended Solids	35 mg/L	15 mg/L
Turbidity, as NTU	-	5.0 ntu
Mercury, as Hg	<0.2 ug/L	<0.2 ug/L

Comments

Respectfully Submitted,



Joel Phillips

Director, Analytical Lab
ChemTreat International, Inc.